TRIDONIC

Emergency lighting units EM powerLED

EM powerLED BASIC 4W

Emergency lighting LED Driver

Product description

- Emergency lighting LED Driver for manual testing
- For self-contained emergency lighting
- SELV for output voltage < 60 V DC
- Low profile casing (21 x 30 mm cross-section)
- 5-year guarantee

Properties

- Non maintained operation
- Constant current mode
- With either screw or clip fastening (clip-fix)
- 1, 2 or 3 h rated duration
- Selectable operating time (jumper)
- Green charge status display LED
- Output power limitation
- Automatic restart after LED replacement
- Electronic multi-level charge system
- SELV (outputs powerLED, battery, status LED, test switch)
- Polarity reversal protection for battery
- Deep discharge protection
- Very low energy consumption from the battery after activation of the deep discharge protection
- Short-circuit-proof battery connection
- Emergency lighting LEDs available

Batteries

- High-temperature cells
- NiCd or NiMH batteries
- 4-year design life
- 1-year guarantee
- For battery compatibility refer to table "Battery selection"
- \rightarrow

Standards, page 5

Wiring diagrams and installation examples, $\mathsf{page}\ 7$



Screw-fix







TRIDONIC


Emergency lighting units EM powerLED

EM powerLED BASIC 4W


Emergency lighting LED Driver

Technical data

Rated supply voltage	220 – 240 V
Mains frequency	50 / 60 Hz
Typ. λ (at 230 V, 50 Hz)	0.34
Forward voltage range LED module (1 \times LED)	2.8 – 3.4 V
Forward voltage range LED module (2 x LED)	5.6 – 6.8 V
Max. open circuit voltage	10 V
LED current in emergency operation (1 x LED)	1.000 mA
LED current in emergency operation (2 x LED)	700 mA
Typ. output power (1 x LED)	3.4 W
Typ. output power (2 x LED)	4.5 W
Time to light	0.23 s from detection of emergency event
Overvoltage protection	320 V (for 1 h)
Battery discharge current	See page 4
Max. casing temperature tc	70 °C
Ambient temperature ta	-25 +45 °C
Mains voltage changeover threshold	according to EN 60598-2-22
Type of protection	IP20



Screw-fix



Clip-fix

Ordering data								
Туре [℗]	Article number	Dimensions L x W x H	Packaging, carton	Packaging, pallet	Weight per pc.	Max. number Power of LED		
Screw fastening version								
EM powerLED 4 W BASIC	89800122	139 x 30 x 21 mm	25 pc(s).	1,200 pc(s).	0.068 kg	2 4 W		
EM powerLED 4W BASIC NiMH	89800444	139 x 30 x 21 mm	25 pc(s).	1,200 pc(s).	0.068 kg	2 4 W		
Clip fastening version								
EM powerLED 4 W BASIC	89800121	127 x 30 x 21 mm	25 pc(s).	1,200 pc(s).	0.068 kg	2 4 W		

Specific technical data

Туре ^ℤ		Mains	current in charging o	peration	Mains power in charging operation			
	Rated duration	Initial charge	Fast recharge	Trickle charge [®]	Initial charge	Fast recharge	Trickle charge [®]	
EM powerLED 4 W BASIC	1 h	21.0 mA	27.5 mA	15.2 mA	2.0 W	3.0 W	1.2 W	
EM powerLED 4 W BASIC	2 h	27.5 mA	32.4 mA	21.0 mA	3.0 W	3.7 W	2.0 W	
EM powerLED 4 W BASIC	3 h	27.5 mA	32.4 mA	21.0 mA	3.0 W	3.7 W	2.0 W	
EM powerLED 4 W BASIC NiMH	1 h	19.0 mA	24.0 mA	13.0 mA	1.7 W	2.4 W	1.0 W	
EM powerLED 4 W BASIC NiMH	2 h	30.0 mA	32.0 mA	13.0 mA	3.1 W	3.3 W	1.1 W	
EM powerLED 4 W BASIC NiMH	3 h	30.0 mA	32.0 mA	13.0 mA	3.1 W	3.3 W	1.1 W	

[®] For EM powerLED 4 W BASIC NiMH: average over 20 min. (4 min. charge / 16 min. off)

^② EM = Emergency

Emergency lighting units EM powerLED



Test switch EM2

Product description

- For connection to the emergency lighting unit
- For checking the device function



Ordering data

Туре	Type Article number		Packaging, carton	Weight per pc.
Test switch EM 2	89805277	25 pc(s).	200 pc(s).	0.011 kg



Status indication green LED

Product description

• A green LED indicates that charging current is flowing into the battery



Ordering data

Туре	Article number	Packaging, bag	Packaging, carton	Weight per pc.
LED EM green	89899605	25 pc(s).	200 pc(s).	0.011 kg
LED EM green, ultra high brightness	89899756	25 pc(s).	800 pc(s).	0.012 kg

Battery selection

EM powerLED 4W BASIC, 1 / 2 / 3 h

				Туре	EM powerLED 4W BASIC 89800121 / 89800122 5 cells		EM powerLED 4W BASIC NiMH 89800444		
				Article no.					
				Cells			5 cells		
				Duration	1 h	2 / 3 h	1 h	2 / 3 h	
Technology and capacity	-	Number of cells	Туре	Article no.		Assignable	e batteries		
NiCd 4 Ah	stick	1 x 5	Accu-NiCd 5A	89895973		•			
D cells	stick + stick	3 + 2	Accu-NiCd 5C 55	89800090		•			
NiMH 2.2 Ah	stick	1 x 5	Accu-NiMH 5A	28002090	•		•		
Cs cells	side by side	5 x 1	Accu-NiMH 5B	28002093	•		•		
NiMH 4 Ah LA cells	stick + stick	2 + 3	Accu-NiMH 4Ah 5C CON	89800439				•	

Battery charge / discharge data

EM powerLED 4W BASIC, 1 / 2 / 3 h

	Туре	EM powerLE	D 4W BASIC	EM powerLED 4W BASIC NiMH			
	Article no.	89800121 /	/ 89800122	8980	0444		
	Cells	5 c	ells	5 c	ells		
	Duration	1 h	2 / 3 h	1 h	2 / 3 h		
	Initial charge		20	h			
Battery charge time	Fast recharge	10 h	15 h	10 h	15 h		
	Trickle charge		contin	nuously			
	Initial charge	130 mA	250 mA	130 mA	300 mA		
Charge current	Fast recharge	250 mA	330 mA	210 mA	330 mA		
	Trickle charge	60 mA 130 mA		127 mA / 4 min. 0 mA / 16 min.	201 mA / 4 min. 0 mA / 16 min.		
Discharge current		1,100 mA	1,100 mA	1,100 mA	1,100 mA		

Standards

- according to EN 50172
- according to EN 60598-2-22
- EN 61347-2-7
- EN 61347-2-13
- EN 62384
- EN 55015
- EN 61000-2-3
- EN 61000-3-3
- EN 61547
- EN 60068-2-64EN 60068-2-29
- EN 00008-2-29
- EN 60068-2-30

Technical data batteries

Accu-NiCd

4.2 / 4.5 Ah
Battery voltage/cell
Cell type
Case temperature range
to ensure 4 years design life
Max. short term temperature (reduced life-time)
Max. number discharge cycles

1.2 V

+5 °C to +55 °C 70 °C

4 cycles during comissioning

+5°C to +50°C 70°C

30 cycles during

comissioning

6 months

6 months

4 cycles per year plus

6 months

1.2 V Cs

12 cycles per year plus

D

Max. storage time

Accu-NiMH

	Accu-Minin
1	2.2 Ah
	Battery voltage/cell
1	Cell type
1	Case temperature range
	to ensure 4 years design life
	Max. short term temperature (reduced life-time)
	Max. number discharge cycles

Max. storage time

4.0 Ah

Battery voltage/cell	1.2 V
Cell type	LA
Case temperature range	
to ensure 4 years design life	+5 °C to +45 °C
Max. short term temperature (reduced life-time)	70 °C
Max. number discharge cycles	4 cycles per year plus
	30 cycles during
	comissioning

Max. storage time

Batteries

Connection method: 4.8 x 0.5 mm spade tag welded to end of cell

For stick packs this connection is accessible after the battery caps have been fitted.


To inhibit inverter operation disconnect the batteries by removing the connector from the battery spade tag.

For further information refer to corresponding battery datasheet.

Storage, installation and commissioning

Relevant information about storage conditions, installation and commissioning are provided in the battery datasheets.

Duration link selection



Jumper selection

Module supplied with jumper in 3 hours position (position B).

The position of the link will only be read on first power up. If it is changed afterwards both the battery and mains supply must be disconnected for 10 seconds to enable the EM powerLED to read the new link position on reconnection of the battery and mains. It will lead to a false battery failure indication if the link is changed after installation without this reset.

Further technical data

The EM powerLED has a unique power regulation circuit; this is designed to limit the total power drawn from the battery in the event of using LED's with a forward voltage (Vf) higher than 3.4 V.

In such cases the unit will reduce the LED current in order to maintain an acceptable drain current from the battery and hence meet the required duration time. This feature enables the EM powerLED to have minimum battery count for a given range of LED's.

Life-time

Average life-time 50,000 hours under rated conditions with a failure rate of less than 10%. Average failure rate of 0.2% per 1000 operating hours.

Emergency lighting units

EM powerLED

Mechanical details

Case manufactured from polycarbonate.

Glow-wire test according to EN 61347-1 with increased temperature of 850 $^\circ\mathrm{C}$ passed.

LED status indicator

- Green
- Mounting hole 6.5 mm dia
- Lead length 1000 mm

Test switch

- Mounting hole 7.0 mm dia
- Lead length 550 mm

Battery leads


- Quantity: 1 red and 1 black
- Length: 1m
- Wire type: 0.5 mm² solid conductor
- Insulation rating: 90 °C

Battery end termination Push on 4.8 mm receptacle to suit battery spade fitted with insulating cover

Module end termination 8.0 mm stripped insulation

Two-piece batteries are supplied with a 200 mm lead with 4.8 mm receptacles at each end and insulating covers to connect the separate sticks together.

Recommended fixing details for clip fixing



Isolation and electric strength testing of luminaires

Electronic LED Drivers can be damaged by high voltage. This has to be considered during the routine testing of the luminaires in production.

According to IEC 60598-1 Annex Q (informative only!) or ENEC 303-Annex A, each luminaire should be submitted to an isolation test with 500 Vpc for 1 second. This test voltage should be connected between the interconnected phase and neutral terminals and the earth terminal. The isolation resistance must be at least $2 M\Omega$.

As an alternative, IEC 60598-1 Annex Q describes a test of the electrical strength with 1,500 Vac (or 1,414 \times 1,500 Vbc). To avoid damage to the electronic LED Drivers this test must not be conducted.

Maximum loading of automatic circuit breakers

Automatic circuit breaker type	B10	C10	B13	C13	B16	C16	B20	C20	Inrush	current
Installation Ø	1.5 mm ²	1.5 mm ²	1.5 mm ²	1.5 mm ²	2.5 mm ²	2.5 mm ²	2.5 mm ²	2.5 mm ²	max	Time
EM powerLED 4 W BASIC	90	180	130	260	130	260	130	260	10 A	120 µs
EM powerLED 4 W BASIC NIMH	90	180	130	260	130	260	130	260	10 A	120 µs

Wiring type and cross section

Wiring

mains (SL, N, L) LED (LED +, LED –)

Wiring

batteries (Bat +, Bat –) test switch (switch) status indication LED (status K, A)

Use one wire for each terminal connector only.

Max. lead insulation diameter


Battery	2.1 mm
Test switch	2.1 mm
Indicator LED	2.1 mm

Maximum lead length

LED	3 m
status indication LED	1 m
batteries	1m

Release of the wiring

Press down the "push button" and remove the cable from front.



0.5 - 1.5 mm² solid or fine-stranded

8.5 – 9.5 mm


8.5 – 9.5 mm

 $0.5-1.0\ mm^2$ fine-stranded with ferrule

 $0.2 - 0.5 \text{ mm}^2$ solid or fine-stranded 0.25 mm^2 fine-stranded with ferrule

Wiring diagrams

Wiring diagram for one LED or two LED in series



-

Battery

Take care that the LED is connected with the right polarity. LED that are connected to the EM powerLED devices should have a reverse polarity protection device such as a schottky diodes fitted, otherwise irreversible damage could occur if the LED is connected in reverse polarity. Any protection device must be capaple of handling in excess of 1,000 mA.

Note: Please ensure that at the terminal of the EM powerLED module the battery negative is not connected to the negative of the LED load.


Manually tested emergency lighting with combined LED modules for general and emergency lighting (e.g. STARK QLE CLASSIC EM, STARK LLE 24-280-1250 EM, STARK CLE CLASSIC EM, STARK SLE CLASSIC EM):

°O

Due to the fact that independent circuits are used for general and emergency lighting it is important that the normal supply of the mains LED Driver is switched off together with the permanent emergency supply prior to checking the operation of the emergency LEDs.

If this is not done then it may not be possible to see that the emergency LEDs are operating.

Use a circuit similar to that shown next.



* Use 230 V Test switch

Emergency lighting units EM powerLED

Wiring instructions

- The EM powerLED terminals, battery, indicator LED and test switch terminals are classified as SELV. Keep the wiring of the input terminals separated from the wiring of the SELV terminals or consider special wiring (double insulation, 6 mm creepage and clearance) when these connections should be kept SELV.
- The output to the LED is DC but has high frequency content at 125 kHz, which should be considered for good EMC compliance.
- EM powerLED leads should be separated from the mains connections and wiring for good EMC performance. With some luminaires it may be necessary to add a ferrite bead inductor to obtain satisfactory EMC performance.
- Maximum lead length on the EM powerLED terminals is 3 m. For a good EMC performance keep the LED wiring as short as possible.
- Maximum lead length for the test switch and Indicator LED connection is 1m. The test switch and Indicator LED wiring should be separated from the EM powerLED leads to prevent noise coupling.
- Battery leads are specified with 0.5 $\rm mm^2$ cross section and a length of < 1.3 m.
- To avoid the damage of the control gear, the wiring must be protected against short circuits to earth (sharp edged metal parts, metal cable clips, louver, etc.).

Additional information

Additional technical information at <u>www.tridonic.com</u> \rightarrow Technical Data

Guarantee conditions at <u>www.tridonic.com</u> \rightarrow Services

Life-time declarations are informative and represent no warranty claim. No warranty if device was opened.